



Certificate of Analysis

Lab Sample No.: 23C0603-01

Name: Eagle Mountain City (DW)	Sample Date: 3/8/2023 10:26 AM
Sample Site: Well #5	Receipt Date: 3/8/2023 12:41 PM
Comments:	Sampler: Jordan Nielson
Sample Matrix: Drinking Water	Project:
PO Number:	System No.: UTAH25142
Source Code: WS006	Sample Point: WS006
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Inorganic								
Nitrate as N	4.83	10	0.10	mg/L	EPA 300.0	03/08/2023 14:51	03/09/2023 03:07	